

DOLPHIN MARINE MAGIC
KIERAN MARSHALL
65 ORLANDO STREET
COFFS HARBOUR NSW 2450

BATCHNUMBER: 14/1390
No. of SAMPLES: 1
DATE COLLECTED: 02/07/14
DATE RECEIVED: 02/07/14
TIME RECEIVED: 11:05
DATE TESTING COMMENCED:
02/07/14

REPORT OF ANALYSIS

| SAMPLE REFERENCE | SAMPLE DESCRIPTION |
|------------------|---------------------|
| 14/1390/1 | Discharge Point # 1 |


| ANALYSIS | UNITS | 14/1390/1 | | | | METHOD NO |
|------------------------------|-----------|-----------|--|--|--|----------------|
| pH | pH unit | 8.2 | | | | APHA 4500-H+ B |
| Biochem Oxygen Demand (BOD5) | mg/L | <2 | | | | APHA 5210 B |
| Chlorine Total | mg/L | 0.21 | | | | EL11B |
| Total Suspended Solids | mg/L | 3 | | | | APHA 2540 D |
| Total Nitrogen | mg/L | 1.69 | | | | EL30F |
| Total Phosphorus | mg/L | 0.58 | | | | EL18F |
| Faecal Coliforms | cfu/100mL | 0 | | | | APHA 9222 D |

Comments

Sample(s) collected by client and analysed as received in accordance with "Standard Methods for the Examination of Water & Wastewater", 22nd Edition, 2012, APHA. Raw data sheets stating analysis dates are available upon request.

NATA Accreditation does not cover the performance of this service.

Note: Microbiological results are membrane presumptive.

Approved: 
B J Wadleigh
Laboratory Manager

14/07/14



Accredited for compliance with ISO/IEC 17025.
[Accreditation Numbers: 12359 (Chemical) & 14565 (Microbiological)]

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian and International standards.