Page 1 of 1

05/09/16

DOLPHINMARINEMAGIC KIERANMARSHALL 65 ORLANDO STREET COFFS HARBOUR NSW 2450 BATCHNUMBER: 16/1936 No. of SAMPLES: 1 DATECOLLECTED: 05/09/16 DATERECEIVED: 05/09/16 TIMERECEIVED: 13:30 DATETESTING COMMENCED:

REPORT OF ANALYSIS

SAMPLE REFERENCE	SAMPLE DESCRIPTION
16/1936/1	Discharge Point # 1

ANALYSIS	UNITS	16/1936/1		METHODNO
рН	pH unit	8.1		APHA 4500-H+B
Biochem Oxygen Demand	mg/L	<2		APHA 5210 B
(BOD5)				
Chlorine Total	mg/L	0.23		EL11B
Total Suspended Solids	mg/L	38		APHA 2540 D
Total Nitrogen	mg/L	0.70		EL30F
Total Phosphorus	mg/L	0.82		EL18F
Faecal Coliforms	cfu/100mL	0		ELM3

Comments

Sample(s) collected by client and analysed as received in accordance with "Standard Methods for the Examination of Water & Wastewater", 22nd Edition, 2012, APHA. Raw data sheets stating analysis dates are available upon request. Tests marked with '#' are not covered by NATA Accreditation.

Note: Microbiological results are membrane presumptive.

Approved: 🔑 🔾

B J Wadleigh X Laboratory Manager 13/09/16



Accredited for compliance with ISO/IEC 17025.

[Accreditation Numbers: 12359 (Chemical) & 14565 (Microbiological)]

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian and International standards.