

DOLPHIN MARINE MAGIC  
KIERAN MARSHALL  
65 ORLANDO STREET  
COFFS HARBOUR NSW 2450

BATCH NUMBER: 17/2696  
No. of SAMPLES: 1  
DATE COLLECTED: 13/12/17  
DATE RECEIVED: 13/12/17  
TIME RECEIVED: 11:10  
DATE TESTING COMMENCED:  
13/12/17

### REPORT OF ANALYSIS

SAMPLE REFERENCE	SAMPLE DESCRIPTION
17/2696/1	Discharge Point # 1

ANALYSIS	UNITS	17/2696/1				METHOD NO
pH	pH unit	8.1				APHA 4500-H+ B
Biochem Oxygen Demand (BOD5)	mg/L	<2				APHA 5210 B
Chlorine Total	mg/L	0.54				EL11B
Total Suspended Solids	mg/L	3				APHA 2540 D
Total Nitrogen	mg/L	0.77				EL30F
Total Phosphorus	mg/L	0.90				EL18F
Faecal Coliforms	cfu/100mL	0				APHA 9222 D

#### Comments

Sample(s) collected by client and analysed as received in accordance with "Standard Methods for the Examination of Water & Wastewater", 22nd Edition, 2012, APHA. Raw data sheets stating analysis dates are available upon request.

Tests marked with '#' are not covered by NATA Accreditation.

Note: Microbiological results are membrane presumptive.

Report Date: 20/12/17



Accredited for compliance with ISO/IEC 17025.  
[Accreditation Numbers: 12359 (Chemical) & 14565 (Microbiological)]

Approved: G. Giles  
Geraldine Giles - Delegate for

B J Wadleigh  
Laboratory Manager