Page 1 of 1

DOLPHINMARINEMAGIC
No. of SAMPLES:

KIERANMARSHALL
DATECOLLECTED:
05/02/18
65 ORLANDO STREET
DATERECEIVED:
05/02/18
COFFS HARBOUR NSW 2450
TIMERECEIVED:
05/02/18
DATETESTING COMMENCED:
05/02/18

REPORT OF ANALYSIS

SAMPLE REFERENCE	SAMPLE DESCRIPTION				
18/0282/1	Discharge Point # 1				

ANALYSIS	UNITS	18/0282/1		METHODNO
рН	pH unit	8.1		APHA 4500-H+ B
Biochem Oxygen Demand	mg/L	<2		APHA 5210 B
(BOD5)				
Chlorine Total	mg/L	0.15		EL11B
Total Suspended Solids	mg/L	8		APHA 2540 D
Total Nitrogen	mg/L	1.17		EL30F
Total Phosphorus	mg/L	0.59		EL18F
Faecal Coliforms	cfu/100mL	15		APHA 9222 D

Comments

Sample(s) collected by client and analysed as received in accordance with "Standard Methods for the Examination of Water & Wastewater", 22nd Edition, 2012, APHA. Raw data sheets stating analysis dates are available upon request.

Tests marked with '#' are not covered by NATA Accreditation.

Note: Microbiological results are membrane presumptive.

Report Date: 14/02/18

NATA

Accredited for compliance with ISO/IEC 17025. [Accreditation Numbers: 12359 (Chemical) & 14565 (Microbiological)]

Approved:

B J Wadleigh Laboratory Manager