

PET PORPOISE POOL
 SPENCER PICKERING
 65 ORLANDO STREET
 COFFS HARBOUR NSW 2450

BATCH NUMBER: 12/2288
 No. of SAMPLES: 1
 DATE COLLECTED: 23/10/12
 DATE RECEIVED: 23/10/12
 TIME RECEIVED: 12:15
 DATE TESTING COMMENCED:
 23/10/12


REPORT OF ANALYSIS

| SAMPLE REFERENCE | SAMPLE DESCRIPTION |
|------------------|---------------------|
| 12/2288/1 | Discharge Point # 1 |

| ANALYSIS | METHOD NO | UNITS | 12/2288/1 |
|------------------------------|----------------|-----------|-----------|
| pH | APHA 4500-H+ B | pH unit | 8.0 |
| Biochem Oxygen Demand (BOD5) | APHA 5210 B | mg/L | <2 |
| Chlorine Total | EL11B | mg/L | 0.36 |
| Total Suspended Solids | APHA 2540 D | mg/L | 14 |
| Total Nitrogen | EL30F | mg/L | 2.90 |
| Total Phosphorus | EL18F | mg/L | 0.31 |
| Faecal Coliforms | APHA 9222 D | cfu/100mL | 0 |

Comments

Sample(s) collected by client and analysed as received in accordance with "Standard Methods for the Examination of Water & Wastewater", 21st Edition, 2005, APHA. Raw data sheets stating analysis dates are available upon request.

Approved: 
 B J Wadleigh
 Laboratory Manager

31/10/12



This document is issued in accordance with NATA's accreditation requirements.

Accredited for compliance with ISO/IEC 17025.
 [Accreditation Numbers: 12359 (Chemical) & 14565 (Microbiological)]

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.