

DOLPHIN MARINE MAGIC
KIERAN MARSHALL
65 ORLANDO STREET
COFFS HARBOUR NSW 2450

BATCHNUMBER: 14/2579
No. of SAMPLES: 1
DATE COLLECTED: 08/12/14
DATE RECEIVED: 08/12/14
TIME RECEIVED: 13:50
DATE TESTING COMMENCED:
08/12/14

REPORT OF ANALYSIS

SAMPLE REFERENCE	SAMPLE DESCRIPTION
14/2579/1	Discharge Point # 1


ANALYSIS	UNITS	14/2579/1				METHOD NO
pH	pH unit	7.9				APHA 4500-H+ B
Biochem Oxygen Demand (BOD5)	mg/L	<2				APHA 5210 B
Chlorine Total	mg/L	0.24				EL11B
Total Suspended Solids	mg/L	4				APHA 2540 D
Total Nitrogen	mg/L	1.14				EL30F
Total Phosphorus	mg/L	0.26				EL18F
Faecal Coliforms	cfu/100mL	0				APHA 9222 D

Comments

Sample(s) collected by client and analysed as received in accordance with "Standard Methods for the Examination of Water & Wastewater", 22nd Edition, 2012, APHA. Raw data sheets stating analysis dates are available upon request.

Tests marked with an '#' are not covered by NATA Accreditation.

Note: Microbiological results are membrane presumptive.

Approved: 
B J Wadleigh
Laboratory Manager

15/12/14



Accredited for compliance with ISO/IEC 17025.
[Accreditation Numbers: 12359 (Chemical) & 14565 (Microbiological)]

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian and International standards.