

DOLPHIN MARINE MAGIC  
KIERAN MARSHALL  
65 ORLANDO STREET  
COFFS HARBOUR NSW 2450

BATCHNUMBER: 15/2037  
No. of SAMPLES: 1  
DATE COLLECTED: 01/10/15  
DATE RECEIVED: 01/10/15  
TIME RECEIVED: 11:35  
DATE TESTING COMMENCED:  
01/10/15

### REPORT OF ANALYSIS

SAMPLE REFERENCE	SAMPLE DESCRIPTION
15/2037/1	Discharge Point # 1

ANALYSIS	UNITS	15/2037/1				METHOD NO
pH	pH unit	8.1				APHA 4500-H+ B
Biochem Oxygen Demand (BOD5)	mg/L	<2				APHA 5210 B
Chlorine Total	mg/L	0.36				EL11B
Total Suspended Solids	mg/L	2				APHA 2540 D
Total Nitrogen	mg/L	0.90				EL30F
Total Phosphorus	mg/L	0.57				EL18F
Faecal Coliforms	cfu/100mL	0				APHA 9222 D

#### Comments

Sample(s) collected by client and analysed as received in accordance with "Standard Methods for the Examination of Water & Wastewater", 22nd Edition, 2012, APHA. Raw data sheets stating analysis dates are available upon request.

Tests marked with '#' are not covered by NATA Accreditation.

Note: Microbiological results are membrane presumptive.

Approved: 

B J Wadleigh  
Laboratory Manager

12/10/15



Accredited for compliance with ISO/IEC 17025.  
[Accreditation Numbers: 12359 (Chemical) & 14565 (Microbiological)]

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian and International standards.